

Annual Drinking Water Quality Report 2024

Harris County Municipal Utility District 71
TX1011823

ABOUT THIS REPORT

Our Drinking Water meets or exceeds all Federal and State Drinking Water Requirements. This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required testing. We hope this information helps you become more knowledgeable about what is in your drinking water.

SPECIAL NOTICE FOR THE ELDERLY, INFANTS, CANCER PATIENTS, PEOPLE WITH IMMUNE PROBLEMS

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

En Espanol

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (281) 897-9100.

WHERE DO WE GET OUR WATER?

Harris County Municipal Utility District (MUD) 71 provides drinking water from one source:

- Groundwater from four (4) wells within the Evangeline aquifer located in Harris County

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. To ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Contaminants may be found in drinking water that may cause taste, color or odor problems. The presence of contaminants does not necessarily indicate that water poses a health risk. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791 and/or Regional Water Corporation at (281) 897-9100.

The Texas Commission on Environmental Quality (TCEQ) completed an assessment of your source water, and results indicate that our sources have a low susceptibility to contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report (CCR). For more information on source water assessments and protection efforts at our system, contact us at 281-897-9100.

PUBLIC PARTICIPATION OPPORTUNITIES

Date: Second Monday of each month

Time: 6:00 P.M.

Location: 21437 Clay Road, Katy, Texas 77449

Phone Number: 281-897-9100

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us at (281) 897-9100.

DRINKING WATER CONTAMINANTS

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

ARSENIC

While your drinking water meets the EPA's standard for arsenic, it does contain low levels of arsenic. The EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Harris County MUD 71 is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

SECONDARY CONSTITUENTS

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color and odor issues. Taste and color constituents, called secondary constituents, are regulated by the state of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondary constituents are not required to be reported in this document, but they may affect the appearance and taste of your water. For more information on taste, odor, or color of drinking water, please contact us (281) 897-9100.

WATER QUALITY DATA

The state of Texas allows for some contaminants to be monitored less than once per year because the concentrations do not change frequently. The year that each result was detected is indicated in the tables below. Definitions, abbreviations, and sources of detected contaminants can be found on pages 8 and 9 of this report.

HARRIS COUNTY MUD 71

INORGANIC CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2022	Arsenic	0.0072	0.0072 - 0.0072	0.01	0	mg/L	No
2022	Barium	0.171	0.171 - 0.171	2	2	mg/L	No
2023	Fluoride	1.06	1.06 - 1.06	4	4	mg/L	No
2024	Nitrate (measured as nitrogen)	ND	ND	10	10	mg/L	No
2022	Selenium	0.0046	0.0046 - 0.0046	0.05	0.05	mg/L	No

RADIOACTIVE CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2020	Gross Alpha excluding radon and uranium	4.5	4.5 - 4.5	15	0	pCi/L	No

SYNTHETIC ORGANIC CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2024	Di (2-ethylhexyl) phthalate	ND	ND	6	0	µg/L	No

DISINFECTANT RESIDUAL - FREE CHLORINE

Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Units	Violation
2024	1.88	0.4 - 2.9	4	4	mg/L	No



WATER QUALITY DATA - CONT'D

DISINFECTION BY-PRODUCTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2024	Trihalomethanes (TTHM)	2	0 - 1.6	80	No goal for the total	µg/L	No
2024	Haloacetic Acids (HAA5)	ND	ND	60	No goal for the total	µg/L	No

*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year.

LEAD AND COPPER

Year	Contaminant	The 90 th Percentile	No. of Sites Exceeding AL	AL	MCLG	Units	Does Constituent Exceed AL?
2022	Lead	0	0	15	0	mg/L	No
2022	Copper	0	0	1.3	1.3	mg/L	No

As part of an ongoing effort to monitor lead and copper in drinking water, the lead service line inventory, completed in 2024, is available for viewing at **Regional Water Corporation's office, located at 13300 Schroeder Road, Houston, Texas 77070 during the hours of 8:00 AM and 4:00 PM, Monday - Friday, with the exception of holidays and extreme weather days.** All portions of the service line are known NOT to be lead or galvanized requiring replacement (GRR) through an evidence-based record, method, or technique.

The Fifth Unregulated Contaminant Monitoring Rule (UCMR 5)

The Safe Drinking Water Act requires that once every five years, EPA issues a list of priority unregulated contaminants to be monitored by certain public water systems across the States, Tribes and Territories. The contaminants may be present in drinking water but are not yet subject to EPA drinking water standards. The five-year UCMR 5 cycle spans 2022 – 2026. UCMR 5 includes 30 contaminants, 29 Per- and Polyfluoroalkyl Substances (PFAS) and one (1) metal/pharmaceutical, lithium (Li). The data collected under UCMR 5 will help the EPA understand the frequency that these contaminants are found in the nation's drinking water systems and at what levels. This data will help inform EPA regulatory determinations and risk-management decisions and ensure science-based decision-making.

The following table includes any unregulated contaminant detected during analyses and the amount detected.

UCMR 5 CONTAMINANTS – HARRIS COUNTY MUD 71

Date Collected	Analyte	Highest Level Detected	Range of Levels Detected	Units
1/17/2024	Lithium	50.2	40.2 – 50.2	µg/L
8/16/2024	Lithium	49.2	41.9 – 49.2	µg/L

The data is also publicly available here: <https://www.epa.gov/dwucmr/fifth-unregulated-contaminant-monitoring-rule-data-finder>



Special Notice for Availability of Unregulated Contaminant Monitoring Data Template 3-9

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Availability of Monitoring Data for Unregulated Contaminants for Harris County MUD 71

Our water system has sampled a series of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by the EPA. The purpose of monitoring for these contaminants is to help the EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that this data is available. If you are interested in examining the results, please contact Dawn Olivo at (281) 897-9100 or at 13300 Schroeder Road, Houston, Texas 77070.

The data is also publicly available here: <https://www.epa.gov/dwucmr/fifth-unregulated-contaminant-monitoring-rule-data-finder#data-finder>

This notice is being sent to you by Harris County MUD 71, State Water System ID# 1011823.

Date distributed: 7/1/2025

CONTAMINANTS AND SOURCES

CONTAMINANT	SOURCE
Arsenic	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	Discharge of drilling wastes; Discharge from metal refineries. Erosion of natural deposits.
Beta/photon emitters	Decay of natural and man-made deposits.
Chlorine Residual, Free	Water additive used to control microbes.
Copper	Corrosion of household plumbing systems erosion of natural deposits.
Di (2-ethylhexyl) phthalate	Discharge from rubber and chemical factories.
Fluoride*	Erosion of natural deposits; Discharge from fertilizer and aluminum factories; Water additive which promotes strong teeth.
Gross Alpha emitters	Erosion of natural deposits.
Lead	Corrosion of household plumbing systems; erosion of natural deposits.
Lithium (Li)	Naturally occurring metal that may concentrate in brine waters; lithium salts are used as pharmaceuticals, used in electrochemical cells, batteries and in organic syntheses.
Nitrate	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Total Trihalomethanes (TTHM)	By-product of drinking water disinfection.
Total Haloacetic Acids (HAA5)	By-product of drinking water disinfection.

*Harris County MUD 71 does not treat source water with fluoride.

DEFINITIONS AND ABBREVIATIONS

Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Avg	Regulatory compliance with some MCLs is based on running annual average of monthly samples.
Level 1 Assessment	A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system
Level 2 Assessment	A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level (MCL)	The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology
Maximum Contaminant Level Goal (MCLG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level (MRDL)	The highest level of disinfectant is allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal (MRDLG)	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	Million fibers per liter (a measure of asbestos)
µg/L	Micrograms per liter = ppb; This unit indicates the amount of a substance (in micrograms) dissolved or present in one liter of a liquid.
mg/L	Milligrams per liter = ppm; This unit indicates the amount of a substance (in milligrams) dissolved or present in one liter of a liquid.
NA	Not Applicable or MCL not regulated
ND	Non-detect. Indicates a contaminant was not detected in the sample. If contaminant was present, it was below the detection limit for the laboratory test.
pCi/L	Picocuries per liter (a measure of radioactivity); One pCi/L is equivalent to two atoms disintegrating per minute per liter.